



# Effective Use of Accelerators

**Kazuro Furukawa**

**<kazuro.furukawa@kek.jp>**

**for SuperKEKB Linac division**




# Experience and plan at KEK's electron / positron complex

- ◆ **Disaster**
- ◆ **Overview of SuperKEKB and complex**
  - ❖ **KEKB 1998 ~ 2010**
  - ❖ **SuperKEKB 2015 ~ (We don't delay the project even with disaster)**
- ◆ **Effective use of accelerators**
  - ❖ **Based on well-designed devices and controls**

# Earthquake in March 2011 – Thanks

- ◆ Thank you so much for your warm messages from all over the world.



- ◆ Operation for PF, PF-AR recovered by June 2011, whole Linac recovery by March 2013, hopefully.


# Linac in SuperKEKB Project

## ◆ 40-times higher Luminosity

- ❖ Twice larger storage beam → Higher Linac beam current
- ❖ 20-times higher collision rate with nano-beam scheme
  - ✧ → Low-emittance Linac injection beam
  - ✧ → Shorter storage lifetime → Higher Linac beam current

## ◆ Linac challenges

- ❖ Low emittance  $e^-$ 
  - ✧ High-charge RF-gun
- ❖ Low emittance  $e^+$ 
  - ✧ Damping ring
- ❖ Higher  $e^+$  beam current
  - ✧ New capture section
- ❖ Beam transport
- ❖ Four ring manipulation



# SuperKEKB Injector Linac

## ◆ Higher Injection Beam Current

- ❖ To Meet the larger stored beam current and shorter beam lifetime in the ring
- ❖ 4~8-times larger bunch current for electron and positron
- ❖ Reconstruction of positron generator, etc

## ◆ Lower-emittance Injection Beam

- ❖ To meet nano-beam scheme in the ring
- ❖ Positron with a damping ring
- ❖ Electron with a photo-cathode RF gun
- ❖ Emittance preservation by alignment and beam instrumentation

## ◆ Quasi-simultaneous injections into 4 storage rings

- ❖ SuperKEKB  $e^-/e^+$  rings, and light sources of PF and PF-AR
- ❖ Improvements to beam instrumentation, low-level RF, controls, timing, etc

# Effective Use of Linac for SuperKEKB, PF, PF-AR

## ◆ Top-up Injections to all of Four Rings (from 2015~)

### ❖ SuperKEKB e<sup>-</sup>/e<sup>+</sup> rings, and light source PF

✧ the same as in KEKB-PF

### ❖ Light source PF-AR should not interfere SuperKEKB rings

✧ Lifetime of SuperKEKB rings are expected to be ~10minutes

## ◆ Fast switching of beams

### ❖ 3.5-times different energies, 100-times different bunch charges

### ❖ Fast controllable magnets, low-level RF, high-power RF, guns, injection systems, independent ring circumference compensations, beam instrumentations (prepared since 2006)

### ❖ Very tricky

### ❖ Event-based fast controls

## ◆ Controls are the essential part of accelerator

### ❖ To make use of it

# Typical Top-up Stored Beam Current Stabilities

## ◆ Beam current were kept stable (Apr.2009~Jun.2010)


❖ Led to good physics, etc. experimental results

❖ KEKB (~0.05%)

HER e<sup>-</sup>: 1107 ± 1mA


LER e<sup>+</sup>: 1585 ± 1mA

❖ PF: 450 ± 0.05mA (~0.01%)










Time: 2010/02/15 09:46:27  
 Beam Current: 449.9 [mA]  
 Lifetime : 0.0 [hours]  
 [\*τ : 0.0 [A·min]  
 Vacuum : 2.1E-8 [Pa]  
 Idt: 7000.0 [A·h]

BL01 CLOSE	BL02 OPEN	BL03 OPEN	BL04 OPEN
BL05 OPEN	BL06 OPEN	BL07 OPEN	BL08 OPEN
BL09 OPEN	BL10 OPEN	BL11 OPEN	BL12 OPEN
BL13 OPEN	BL14 OPEN	BL15 OPEN	BL16 OPEN
BL17 OPEN	BL18 OPEN	BL19 OPEN	BL20 CLOSE
BL21 OPEN	BL22	BL23	BL24
BL25	BL26	BL27 OPEN	BL28 OPEN



# Change in Operation Modes at KEKB



Linac provided basis of robust operation and daily advances in KEKB So in SuperKEKB as well


May.2000

Apr.2003

Dual Bunch  $e^+$

Feb.2005  
Continuous  
Injections

Dec.2008  
Crab Cavities and  
Simultaneous Injection





# SuperKEKB Controls/Operations

## ◆ Inherit Good part of KEKB Controls

- ❖ EPICS

- ❖ Scripting languages

## ◆ Two Additional Concepts

- ❖ Channel Access Everywhere

- ❖ Dual-layer Controls (EPICS and Event-based controls)



# 1st: CA Everywhere

## ◆ EPICS Channel Access (CA) Everywhere


- ❖ Embed EPICS control software (IOC) everywhere possible
- ❖ Reduce efforts on protocol design, testing, maintenance, etc

# Embedded EPICS IOCs at SuperKEKB

## ◆ The same software framework on every controller

✧ Rapid development and smooth maintenance

- ❖  $\mu$ TCA LLRF module: Linux/FPGA
- ❖ Yokogawa PLC: Linux CPU
- ❖ Oscillo. 50Hz measurement: Windows
- ❖ MPS management :Linux/FPGA
- ❖ Timing TDC: Linux/Arm
- ❖ Power modulator and LLRF: Linux/FPGA
- ❖ Libera BPM at 50Hz: Linux/FPGA
- ❖ NI cRIO : CAS/FPGA
- ❖ Many more...





## 2nd: Dual-layer Controls

- ◆ **Another layer in addition to EPICS/CA**
  - ❖ **Event system helps EPICS with another channel/layer**
  - ❖ **Additional functionality, synchronization and speed**


# Dual-layer Controls

## ◆ IOC controls via Conventional EPICS CA

✧ Above 1ms, ordered controls


## ◆ Fast FPGA controls via SFP/Fiber

✧ 10ps ~ 100ms, 114MHz synchronous controls



# Fast, Global, and Synchronous Controls

- ◆ MRF's series-230 Event Generator / Receivers
- ◆ VME64x and VxWorks v5.5.1
- ◆ EPICS R3.14.9 with DevSup v2.4.1
- ◆ 17 event receivers for now
- ◆ 114.24MHz event rate, 50Hz fiducial
- ◆ More than **hundred** 50Hz-analog/timing param.
- ◆ Multi/single-mode fiber
- ◆ Timing precision is  $< 10\text{ps}$ .  
❖  $< 1\text{ps}$  with external module.




# Event-based Control Components

- ◆ **Great combination of commodity devices**
  - ❖ **FPGA (field-programmable gate array) and SFP (small form-factor pluggable)**
- ◆ **In SuperKEKB we will utilize**
  - ❖ **MRF's VME modules (cPCI, PMC, etc possible)**
  - ❖ **SINAP's VME and PLC modules**
  - ❖ **FPGA-SFP-based controllers**
  - ❖ **Event delivery even over Ethernet**
    - ✧ **Error rate over Ethernet  $< 10^{-7}$**
- ◆ **~200 analog/binary control points every 20ms and many more sync. measurements**

# One Machine, Multiple Virtual Accelerators (VAs)


- ◆ Independent parameter set for each VA, one of VAs is active at a time





# Multiple Closed Loop Controls Overlapped

- ◆ Closed loops can be installed on each VA independently
  - ❖ Tested at KEKB





# Summary

- ◆ **We can make use of accelerators efficiently and effectively**
- ◆ **Use of event-based controls as well as (embedded-) EPICS, and scripting languages, will be essential for advanced operations**



Thank You for Your Patience

